

RA14	RISK ASSESSMENT	
-------------	------------------------	---

Operation/Activity:	Asbestos and Asbestos containing materials
----------------------------	---

Site / Location:	All Sites
-------------------------	------------------

Persons at Risk (tick appropriate boxes)			
Employee	✓	Pregnant Women	✓
Visitor	✓	Disabled Persons	✓
General Public	✓	Lone Workers	✓
Young Persons		Others	

GUIDE TO RATINGS:

Risk Severity		Risk Likelihood		Risk Rating	
1	Negligible	1	Unlikely	1 - 6	Low
2	Minor	2	Possible	7 - 14	Medium
3	Significant	3	Quite Possible	15 - 25	High
4	Major	4	Likely		
5	Catastrophic	5	Very Likely		

Overall Risk Rating = Low

Describe the hazards associated with the activity/operation.						
--	--	--	--	--	--	--

		Risk Rating (Before Controls)	Summary of Assessment Overleaf			
			Likelihood (L)	Severity (S)	Risk (L x S)	Risk Rating
H1	Health hazards associated with asbestos – asbestosis, lung cancer, mesothelioma, laryngeal cancer.	High	2	2	4	Low

Assessed By:	Craig Knights	Date	18/12/2025
Reviewed By:		Date:	
Approved By:	Gary Robinson	Date:	18/12/2025

Hazard	Risk Control Measures	Residual Risk		
		Likelihood	Severity	Risk

RA14	RISK ASSESSMENT			
-------------	------------------------	---	--	--

General	- Adequate information, instruction and training shall be given to those who may come across asbestos during their work. - At a minimum this will include regular attendance and completion of Asbestos Awareness training from a reputable and accredited provider.			
H1	If during normal works the possibility of an asbestos containing material is identified, then it will be treated as asbestos containing, until testing proves otherwise.	2	2	4
	The material will be left in place and shall not be worked on in any way.			
	The operative or site supervisor will inform the office of the suspected presence of asbestos and seek further advice on how the intended works are to proceed			
	If removal of the Asbestos after it has been confirmed to be asbestos is required this will be carried out by a suitably qualified asbestos removal contractor. Work will not re-commence until an asbestos clear certificate has been received.			